

Emission Test Certificate

Friday 18th August 2023

Supplier James Hardie Australia Pty Ltd (10 Colquhoun Street, ROSEHILL, NSW, 2142, Australia)
Product Name Villaboard, Versilux and Hardiegroove Source Material
Date Tested August 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)
Test Method ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hours)

Specification Green Building Council of Australia Green Star – Design & As Built V1.3-13.2 Green Star Interiors V1.3-12.2	Villaboard, Versilux and Hardiegroove Source Material – 6mm thickness
Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.025 mg/m ² /hr
Formaldehyde Emission Rate Limit: ≤0.100 mg/m ² /hr	Formaldehyde Emission Rate: 0.006 mg/m ² /hr



Dr. Vyt Garnys
Ph.D., BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr Tuan Duong
Ph.D., B.Eng. (Chemical)
Senior Consultant

Issued Date: 18/8/2023

Expired Date: 18/8/2028

P23080006